COUNTY AGENDA REQUEST

Department:	Animal Control	Presenter(s):	Chief Allen McCullough and Greg Own
Meeting Date:	Wednesday, June 6, 2012	Type of Request:	Old Business

Wording for the Agenda:

Discussion of staff's recommendation that the Animal Shelter be tied into the Peachtree City sewer system.

Background/History/Details:

From FY2009-FY2012 approximately $8,700 has been spent on the Animal Control Department's septic tank and drain field. The system is currently having problems and research has been conducted into tying into the sewer line for the Rite Aid property. Three years ago the County installed a new tank 2" pipe and a pump to pump the liquid to a new drain field and the drain field has failed. The distance from the sanitary sewer system is approximately 330 feet. Plan would be to install an additional manhole on the County property and install a 6" sewer pipe to the Peachtree City sewer drain. From the new sewer drain on County property install approximately 500 feet of 2" pvc to the existing pump. The 2" pipe would be installed around the perimeter of the property in a manner that would not interfere with any proposed construction for a new facility. The 6" pipe would be installed by an outside source and the 2" pipe would be installed in-house by the Maintenance Department. The County would need to get permission from Peachtree City for the sewer tie in. Building Maintenance currently has a quote of $5,600 to complete the needed repair. As an alternative Public Health, Building Maintenance, and Public Safety recommend tying onto the PTC sewer system as the best option.

The quote to repair the current problem is $5,600. The current repair or the recommended alternative to connect to Peachtree City sewer are not included in the current FY2012 or projected FY2013 budget, thus funds would need to come from the undesignated reserve fund.

What action are you seeking from the Board of Commissioners?

The department is requesting funding to complete this project in an amount not to exceed $30,000 and for this request to be placed on the next Thursday meeting which is June 14, 2012 for Board of Commissioners consideration.

If this item requires funding, please describe:

The cost for this project would not exceed $30,000 which would need to be transferred from the undesignated general fund.

Has this request been considered within the past two years?	Yes	If so, when?	
Is Audio-Visual Equipment Required for this Request?*	No	Backup Provided with Request?	No

**** All audio-visual material must be submitted to the County Clerk's Office no later than 48 hours prior to the meeting. It is also your department's responsibility to ensure all third-party audio-visual material is submitted at least 48 hours in advance.***

Approved by Finance	Yes	Reviewed by Legal	Yes
Approved by Purchasing	Not Applicable	County Clerk's Approval	Yes
Administrator's Approval	Yes		

Staff Notes:

ANIMAL SHELTER DRAIN FIELD

Three years ago the County installed a new tank 2” pipe and a pump to pump the liquid to a new drain field. This drain field has failed.

The County property boarders the Rite Aid Property.

The distance from the sanitary sewer system is approximately 330’.

The plan would be to install an additional manhole on the County property and install a 6” sewer pipe to the Peachtree City sewer drain.

From the new sewer drain on county property install approximately 500’ of 2” pvc to the pump that already exist. The 2” pipe would be installed around the perimeter of the property in a manner that would not interfere with any proposed construction for a new facility.

We would still need to get permission from Peachtree City for the sewer tie in.

The 6” would be installed by an outside source and the 2” would be installed in-house by the Maintenance Department.