COUNTY AGENDA REQUEST

Department:	Water System	Presenter(s):	Tony Parrott
Meeting Date:	Thursday, October 11, 2012	Type of Request:	Consent

Wording for the Agenda:

Approval of the Water Committee's recommendation that the Water System will no longer use the Willowbend Well in Peachtree City as a water source.

Background/History/Details:

The Willowbend Well, which is the located in Peachtree City, is the oldest water source in the Fayette County Water System, and it was the original water source for Peachtree City.

Annual water testing by the Drinking Water Program has revealed .53 parts per billion (ppb) of tetrachloroethylene. According to the State of Georgia, the approved Maximum Contaminate Level (MCL) level for tetrachloroethylene is 5 ppb, meaning it meets state standards and is safe to drink. The purpose for this request is based on a low production rate at 60,000 gallons per day.

Simply stated, the Willowbend Well is not necessary as a water source.

What action are you seeking from the Board of Commissioners?

Approval of the Water Committee's recommendation that the Water System will no longer use the Willowbend Well in Peachtree City as a water source.

If this item requires funding, please describe:

Not Applicable.

Has this request been considered within the past two years?	No	If so, when?	
Is Audio-Visual Equipment Required for this Request?*	No	Backup Provided with Request?	No

**** All audio-visual material must be submitted to the County Clerk's Office no later than 48 hours prior to the meeting. It is also your department's responsibility to ensure all third-party audio-visual material is submitted at least 48 hours in advance.***

Approved by Finance	Not Applicable	Reviewed by Legal	Yes
Approved by Purchasing	Not Applicable	County Clerk's Approval	Yes
Administrator's Approval	Yes		

Staff Notes: