

Purchasing Department

140 Stonewall Avenue West, Ste 204 Fayetteville, GA 30214 Phone: 770-305-5420 www.fayettecountyga.gov

November 3, 2023

Subject:

Request for Quotes 2336-A: Lake Kedron Dam Intake Sluice Gate

Addendum 4

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quote. You will need to consider this information when preparing your quote.

- 1. Does the proposed gate have a gear?
 - No gear. It shall be a hand wheel operator.
- 2. What height should the hand operator be mounted?

Same as the hand operator on the sluice gate floor stand adjacent to the where the new one will be mounted.

- 3. Who was the design engineer?
 - Mallet & Associates
- 4. What is the electrical setup?

The electrical outlet on the floor near the intake riser access is for the associated security system for the intake building.

- 5. Are there any level sensors?
 - No level sensors
- 6. Please refer to Attachment 1 for the as built drawings.

Received by (Name):	Company
it is returned not s	t returned to the Fayette County Purchasing Department or if signed, responding individuals or companies will still be requirements of this addendum and the specifications or

The dates for this RFQ were changed in previous addenda as follows:

- a. Addendum 1 changed the pre-quote meeting to 9:00 a.m. on Thursday, November 2, 2023
- b. Addendum 2 changed the questions due date to 3:00 p.m., Tuesday, November 7, 2023
- c. Addendum 2 changed the quotes due: 3:00 p.m., Tuesday, November 14, 2023

Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,

Ted L. Burgess

Director of Purchasing

Attachment 1

