



Fayette COUNTY

"WHERE QUALITY
IS A LIFESTYLE"

PURCHASING DEPARTMENT
140 STONEWALL AVENUE WEST, STE 204
FAYETTEVILLE, GEORGIA 30214
PHONE: 770-305-5420
www.fayettecountyga.gov

July 29, 2016

Subject: #1143-B, Emerald Lake Dam Rehabilitation – Addendum #3

Dear Gentlemen & Ladies:

Please find below information in response to a question we received regarding the invitation to bid for the Emerald Lake Dam rehabilitation. You will want to consider this additional information when preparing your bid. Please acknowledge receipt of this addendum by signing in the space provided below, and return it with your bid.

Question: Since the bridge is not fully designed, and it is the responsibility of the contractor to provide final design, does the contractor have the option of using an alternate concrete beam type than the hollow core slabs shown on sheet S-310?

Response: Contractors shall price and bid the project as defined in the plans and specifications. Alternate bids, other than those specifically requested in the bid schedule, will not be accepted. For the bridge, this means the design shall be the "precast, pre-stressed concrete box beam" (aka hollow core slabs) as indicated on Sheet S-310.

Received by _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department, or if it is returned unsigned, the responder shall still be responsible for the requirements of this addendum and the specifications or changes herein.

Please note: The opening date for this invitation to bid is changed to **3:00 pm, Friday, August 5, 2016**. The Purchasing Department must receive your bid at the above address by or before the opening time and date. The time for submitting questions has expired, so we cannot accept any additional inquiries.

Sincerely,

Ted L. Burgess
Director of Purchasing
(770) 305-5393
tburgess@fayettecountyga.gov