



# Fayette COUNTY

“WHERE QUALITY  
IS A LIFESTYLE”

**PURCHASING DEPARTMENT**  
140 STONEWALL AVENUE WEST, STE 204  
FAYETTEVILLE, GEORGIA 30214  
PHONE: 770-305-5420  
www.fayettecountyga.gov

July 27, 2016

**Subject: #1143-B, Emerald Lake Dam Rehabilitation – Addendum #2**

Dear Gentlemen & Ladies:

Please find below information in response to questions we received regarding the above-referenced invitation to bid. You will want to consider this additional information when preparing your bid. Please acknowledge receipt of this addendum by signing in the space provided below, and return it with your bid.

**Question:** We are having trouble finding a prestress concrete manufacturer that can cast the box beams on the plans. Has the engineer worked with any manufacturers that can do this work? Will you share the prestress concrete companies please.

**Response:** As required in the Bid Package, the bridge manufacturer/supplier must be on GDOT’s Qualified Products List No. 9. This list contains over 20 companies that should be able to design and manufacture a product that meets the specifications.

The bridge cross-section shown on Plan Sheet S-310 and the associated specifications in Section 32 34 35 do not constitute a full bridge design. Instead, the Bid Package establishes minimum standards required for the bridge (width, span, design load, etc.) and requires the Contractor and manufacturer/supplier to develop the design they feel is most cost effective. Per the specifications, the design shall be by a PE.

**CORRECTION ON SHEET S-310:** As noted in Addendum No. 1, utilities shall be routed below the dam, not attached to the bridge.

Received by \_\_\_\_\_ Company \_\_\_\_\_

Note: If this addendum is not returned to the Fayette County Purchasing Department, or if it is returned unsigned, the responder shall still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this invitation to bid remains unchanged, at 3:00 pm, Tuesday, August 2, 2016. The Purchasing Department must receive your bid at the above address by or before the opening time and date.

Sincerely,



Ted L. Burgess  
Director of Purchasing  
(770) 305-5393  
[tburgess@fayettecountyga.gov](mailto:tburgess@fayettecountyga.gov)