

April 3, 2020

Subject: ITB #1795-B: Kenwood Road & Mercedes Trail Culvert Replacements - Addendum #3

Gentlemen/Ladies:

1. **The plans only show a detail for precast box culverts. Is the intent for precast culverts with precast headwalls, Precast culvert with poured in place headwalls or can the culvert and headwalls be poured in place?**

Pre-cast or Cast in place box culvert(s) and headwalls which meet the project plans and specifications is acceptable.

2. **Will the box culvert and wingwalls be precast or cast in place?**

Pre-cast or Cast in place box culvert(s) and headwalls which meet the project plans and specifications is acceptable.

3. **Will Fayette County accept cast-in-place culverts as an alternate to the pre-cast culverts shown in the plans if the contract completion dates are able to be met?**

Pre-cast or Cast in place box culvert(s) and headwalls which meet the project plans and specifications is acceptable.

4. **Will Fayette County please add pay items for guardrail and guardrail anchors?**

Guardrail and Guardrail anchor pricing should be included in the Roadway Construction line item.

Please Note: In conformance with newly-issued State guidance for addressing the coronavirus issue, we are in the process of making modifications for the bid opening on April 8, 2020 at 3:00 p.m. It is planned to hold the bid opening without vendors or other non-county employees physically present. Instead, we will hold a virtual bid opening, with bidders able to view the proceedings via Microsoft Teams or possibly another service. We will issue a follow-up addendum as soon as we have the particulars, including a web address you can use to view the opening.

If, for some reason, the bid opening is suspended or cancelled, all bids will be held un-opened until the bid opening is re-scheduled or will be returned to the bidder upon request.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 3:00 p.m. Bids must be received by the Purchasing Department at the address above, Suite 204, at or before 12:00 noon on the opening date.**

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150 fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing