

October 14, 2020

**Subject: RFQ #1885-B: Brockton Court Culvert Replacement
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Invitation to Bid. You will need to consider this information when preparing your bid.

1. Article 9.02 states that the Owner may at its discretion appoint an engineer to replace Engineer, and that the replacement engineer's status under the Contract Documents shall be that of the former Engineer. POND & Company shall be the Engineer for this project.
2. The following provisions shall be incorporated into the contract documents
 - a. Georgia Department of Transportation (GDOT) specifications as published in the current edition of the Department of Transportation, State of Georgia Standard Specifications Construction of Transportation Systems and Supplemental Specifications are incorporated by reference into the Project Manual and contract documents. They shall supersede all other specifications unless more stringent requirements are listed. It is the responsibility of the Contractor to become familiar with these specifications before bidding and to adhere to them during construction. Copies of the manuals can be obtained from the GDOT website.
 - b. All construction areas abutting lawns and yards or residential or commercial property shall be restored promptly. Finishing, dressing, and grassing shall be accomplished immediately after adequate backfilling strength is obtained as a continuous operation within each area being constructed. Care shall be taken to provide positive drainage to avoid ponding or concentration of runoff. Refer to GDOT Specification 700 for ground preparation requirements.
3. Remove upstream(Type 3) and downstream (Type 1) Rip Rap from project limits and replace with Flexamat, or approved equivalent, along stream banks within upstream and downstream permanent easement areas. No flexamat shall be placed within the stream channel.
4. Fayette County standards can be located at https://library.municode.com/ga/fayette_county/codes/code_of_ordinances.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The bid due date for this ITB has not changed. **The bid due time and date are 12:00 p.m., Tuesday, November 17, 2020.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before 12:00 p.m., Tuesday, November 17, 2020. A virtual bid opening will be held at 2:00 p.m. that day.

Questions regarding this solicitation will be accepted until 3:00 p.m., Wednesday, November 4, 2020. After that, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150 fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing