



Purchasing Department
140 Stonewall Avenue West, Ste 204
Fayetteville, GA 30214
Phone: 770-305-5420
www.fayettedcountyga.gov

April 13, 2021

**Subject: ITB #1937-B: Water Treatment Chemicals
Addendum #2**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

1. **The county has added Liquid Alum and Chlorine Liq. to this Invitation to Bid. The pricing sheet has been updated and is attached. Vendors submitting bids shall use the updated pricing sheet when submitting bids.**
2. **The Scope and Specification has been updated to include the following:**
 11. **Alum shall be delivered by tanker, 12 dry tons per load**
 12. **Specifications for Alum are attached (Attachment A).**

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The due date and opening date for this ITB was updated in Addendum 1 and has not changed. **The bid due time and date are 12:00 p.m., Tuesday, May 11, 2021.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the bid due date and time. A virtual bid opening will be held that day at 3:00 p.m. The bid opening may be viewed here: <https://vimeo.com/user133262656>.

Questions regarding this solicitation will be accepted until 3:00 p.m., Friday, April 23, 2021. After that, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettedcountyga.gov.

Sincerely,

Natasha Duggan for T. Burgess

Ted L. Burgess
Director of Purchasing

PRICING SHEET – updated 4/13/2021
ITB #1937-B: Water Treatment Chemicals

Chemical	Unit Size	Estimated Annual Quantity	Unit Price	Extended Price
Copper Sulfate AWWA B602 - 17	50 lb. bag	20 bags	\$	\$
78% Sulfuric Acid NSF	Ton (2,200 gallons per delivery)	78 tons	\$	\$
Sodium Silica Fluoride AWWA B702 – 18 shall be Prayon Material	50 lb. bag, powder	700 bags	\$	\$
Sodium Hypochlorite AWWA B300-18	15 gal. drum	10 drums	\$	\$
Liquid Alum AWWA #B403-03	dry ton	650 dry tons	\$	\$
Chlorine Liq., AWWA B301-18	1 ton cylinders	66 cylinders	\$	\$

NOTE:

1. All applicable charges shall be included in your total quoted amount, including but not limited to materials, equipment, installation, labor, and any other amounts. No additional charges will be allowed after the quote received by date.

State delivery time after receipt of order: _____ days.

COMPANY NAME _____

1.0 Product Name: Aluminum Sulfate (Liquid Alum)

2.0 Specification:

FEED COMPONENT AND CONCENTRATION RANGE

Chemical Analysis	Specification	
Specific Gravity (SG)	1.33 – 1.34	
Density, lbs./gal, US	11.09 – 11.17	
Al ₂ O ₃ % wet	8.10 – 8.40	
Delivery Temperature	80 – 130 degrees F	
Appearance:	Clear (< 10 NTU)	NO SUSPENDED MATTER
Color:	Colorless to light yellow	
Odor:	Odorless, free from foreign odor	
Must meet NSF 60 certification		

3.0 Additional Requirements:

- 3.1 The supplier shall provide a Safety Data Sheet with each bid submittal.
- 3.2 The supplier shall provide a Certificate of Analysis (CoA) with each load delivered.
- 3.3 The product shall be delivered between 8:00 am and 4:00 pm Monday through Friday. The driver of each delivery will provide a bill of lading with stamped scale weight.
- 3.4 The driver shall be responsible for complete cleanup of any spill(s) originating from the unloading process.