


August 30, 2021

**Subject: RFQ #1982-A: 911 HVAC Replacement
Addendum #1**

Gentlemen/Ladies:


Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

1. **Will the county expect the contractor to provide temporary HVAC while the replacement is underway?**
The county has a portable unit, and the contractor will not need to provide temporary HVAC.
2. **In the Scope of Work, the following is removed: "Remove and properly dispose of existing chiller and all ancillary equipment and materials."**
3. **Where can we set up to lift the new units onto the roof?**
Set up lift will be on the South – side of the building.
4. **Pictures of the inside of the electrical panel are attached.**




5. Pictures of the thermostats being replaced are below.

Radio Room Thermostat



Asst. Dir. Thermostat



6. Are we reinstalling the strike air terminals or do we need to subcontract that work?
Please re-install the strike air terminals.
7. The zone sensor in the radio room is not being replaced.
8. What HVAC repairs have been done since last year?
Only regular preventative maintenance.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00 p.m., Thursday, September 2, 2021.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,

Ted L. Burgess
Director of Purchasing